

VOC Content Test Certificate

Friday, 24th June 2016

Manufacturer: BOSS Fire & Safety (Unit 8/15-23 Kummulla Rd, Caringbah, NSW, 1495).

Sample Description: FireMastic300

Date Tested: June 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

| | |
|--|---|
| <p style="text-align: center;">Specification</p> <p style="text-align: center;">Green Building Council of Australia</p> <p style="text-align: center;">Green Star Design & As Built V1.1 13.1.1</p> <p style="text-align: center;">Green Star Interiors V1.1 12.1.1B</p> | <p style="text-align: center;">FireMastic300</p> |
| <p style="text-align: center;">Acoustic sealants, architectural sealant, waterproofing membranes and sealant, fire retardant sealants and adhesives:</p> <p style="text-align: center;">250 grams per Litre as VOC content per material</p> | <p style="text-align: center;">102 grams per Litre as VOC content per material</p> |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV160641