

# Fire-resistance test on service penetrations in a framed wall system

## Test Report

**Author:** Peter Gordon  
**Report number:** FSP 1833  
**Date:** 28 June 2017

**Client:** Boss Fire & Safety Pty Ltd

Commercial-in-confidence



NATA Accredited Laboratory  
Number: 165  
Corporate Site No 3625  
Accredited for compliance with ISO/IEC 17025 Testing

#### Inquiries should be address to:

Fire Testing and Assessments  
NATA Registered Laboratory  
14 Julius Avenue  
North Ryde, NSW 2113  
Telephone +61 2 9490 5444




Author  
Infrastructure Technologies  
14 Julius Avenue  
North Ryde, NSW 2113  
Telephone +61 2 9490 5500

The Client  
Boss Products (Australia) Pty Ltd  
Unit 8, 15-23 Kumulla Rd  
Caringbah NSW  
Telephone +61 1300 502 677

#### Report Status and Revision History:

VERSION	STATUS	DATE	DISTRIBUTION	ISSUE NUMBER
Revision A	Draft for internal review	31/05/17	CSIRO	FSP 1833
Revision B	Draft	07/06/17	CSIRO and Client	FSP 1833
Revision C	Final for issue	20/06/17	CSIRO and Client	FSP 1833
Revision D	Final for Issue	28/06/17	CSIRO and Client	FSP 1833

#### Report Authorization:

AUTHOR	REVIEWED BY	AUTHORISED BY
Peter Gordon	Heherson Alarde	Brett Roddy
		
28 June 2017	28 June 2017	28 June 2017

## Use of this Report

### **Use of Reports – Testing**

*This report is subject to binding obligations under which it was prepared. In particular, the Report must not be used:*

- *as a means of endorsement; or*
- *in a company prospectus or notification to a Stock Exchange document for capital raising, without the prior written consent of CSIRO.*

*The Report may be published verbatim and in full, provided that a statement is included on the publication that it is a copy of the Report issued by CSIRO.*

*Excerpts of the Report may not be published.*

### **Use of Reports – Consultancy**

*This report is subject to binding obligations under which it was prepared. In particular, the Report may only be used for the following purposes:*

- *the information in the Report may be used by the party that commissioned the Report for its internal business operations (but not licensing to third parties);*
- *the report may be copied for distribution within the organisation that commissioned the Report;*
- *copies of the Report (or extracts of the Report) may be distributed to contractors and agents of the organisation that commissioned the Report who have a need for the Report for its internal business operations. Any extracts of the Report distributed for this purpose must clearly note that the extract is part of a larger Report held by the organisation that commissioned the Report and which has been prepared by CSIRO.*

*The name, trade mark or logo of the CSIRO must not be used without the prior written consent of CSIRO.*

*The Report must not be used as a means of endorsement without the prior written consent of CSIRO.*

## Copyright and disclaimer

© 2017 CSIRO To the extent permitted by law, all rights are reserved and no part of this publication covered by copyright may be reproduced or copied in any form or by any means except with the written permission of CSIRO.

### Important disclaimer

CSIRO advises that the information contained in this publication comprises general statements based on scientific research. The reader is advised and needs to be aware that such information may be incomplete or unable to be used in any specific situation. No reliance or actions must therefore be made on that information without seeking prior expert professional, scientific and technical advice. To the extent permitted by law, CSIRO (including its employees and consultants) excludes all liability to any person for any consequences, including but not limited to all losses, damages, costs, expenses and any other compensation, arising directly or indirectly from using this publication (in part or in whole) and any information or material contained in it.

# Contents

1	Introduction .....	4
1.1	Identification of specimen .....	4
1.2	Sponsor .....	4
1.3	Manufacturer .....	4
1.4	Test standard .....	4
1.5	Reference standard.....	4
1.6	Test number .....	4
1.7	Test date .....	4
2	Description of specimen .....	5
2.1	General.....	5
2.2	Dimensions .....	13
2.3	Orientation.....	13
2.4	Conditioning.....	13
3	Documentation .....	13
4	Equipment.....	13
4.1	Furnace .....	13
4.2	Temperature .....	13
4.3	Measurement system .....	13
5	Ambient temperature .....	14
6	Departure from standard .....	14
7	Termination of test .....	14
8	Test results .....	14
8.1	Critical observations .....	14
8.2	Furnace temperature.....	15
8.3	Furnace severity.....	15
8.4	Specimen temperature .....	15
8.5	Performance .....	15
9	Fire-resistance level (FRL) .....	17
10	Field of direct application of test results .....	17
11	Tested by .....	17
	Appendices .....	18
	Appendix A – Measurement location .....	18
	Appendix B – Test photographs .....	20
	Appendix C – Test data charts.....	24
	Appendix D – Specimen drawings.....	33
	Appendix E – Certificates of Test .....	41
	References.....	48

# Fire-resistance test on service penetrations in a framed wall system

## Sponsored Investigation No. FSP 1833

## 1 Introduction

### 1.1 Identification of specimen

The sponsor identified the specimens as a number of services penetrating a plasterboard wall system with various protection systems.

### 1.2 Sponsor

Boss Products (Australia) Pty Ltd  
Unit 8, 15-23 Kumulla Rd  
Caringbah NSW

### 1.3 Manufacturer

Boss Products (Australia) Pty Ltd  
Unit 8, 15-23 Kumulla Rd  
Caringbah NSW

### 1.4 Test standard

Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4-2014, Fire-resistance tests of elements of construction Section 10: Service penetrations and control joints

### 1.5 Reference standard

Australian Standard 4072, Components for the protection of openings in fire-resistant separating elements, Part 1 - 2005, Service penetrations and control joints.

### 1.6 Test number

CSIRO Reference test number: FS 4676/4100

### 1.7 Test date

The fire-resistance test was conducted on 9 May 2017.



## 2 Description of specimen

### 2.1 General


The specimens comprised seven (7) services penetrating a plasterboard wall and protected by sealants.

For the purpose of the test, the specimens were referenced as Specimen 1, 2, 3, 4, 5, 6, and 7.

Specimen 1 – FireMastic-HPE sealant protecting a 60-mm diameter aperture penetrated by 20-mm PEX Cross Linked Polyethylene plumbing pipe.



SEPARATING ELEMENT	
Plasterboard wall system – Boral Firestop 16-mm plasterboard both sides , with an established FRL of -/90/90	
TYPE AND SIZE OF CONSTRUCTION	
60-mm diameter aperture in a 96-mm thick wall.	
PENETRATING SERVICE	
Description	PEX Cross Linked Polyethylene plumbing pipe. The service penetrated the unexposed side by 2000-mm and the exposed side by 500-mm.
Size	20-mm OD with a wall thickness of 2.3-mm
End conditions	Sealed on the exposed end using SmarteX P 20-mm Push fit brass Pex cap and left open on the unexposed end.
Supports	Approximately 500-mm and 1500-mm away from the wall on the unexposed face.
FIRE STOPPING SYSTEM	
Trade name	FireMastic-HPE sealant
Manufacturer	Boss Fire & Safety Pty Ltd
Description	High Pressure Exerting graphite-based thixotropic acrylic sealant.
Application	The annular gap of 20-mm between the pipe and the plasterboard on both the exposed and unexposed face were sealed with BOSS FireMastic-HPE to a depth of 16-mm (the full depth of plasterboard walls) and finished flush with the surface of the wall.
Photograph	<div>   </div> <div>ExposedUnexposed</div>
Drawing	CSIRO 0517 – 02 dated 26/05/17 by Boss Fire & Safety.

Specimen 2 – FireMastic-300 sealant protecting a 19-mm diameter aperture penetrated by a 19-mm copper pipe lagged with Boss P40-MAK Wrap.



SEPARATING ELEMENT	
Plasterboard wall system – single layer Boral Firestop 16-mm plasterboard on both sides , with an established FRL of -/90/90	
TYPE AND SIZE OF CONSTRUCTION	
19-mm diameter aperture in a 96-mm thick wall.	
PENETRATING SERVICE	
Description	A copper pipe extends 800-mm from the unexposed side, 500-mm from the exposed.
Size	19.05-mm OD with a wall thickness of 1.02-mm.
End conditions	Plugged with Boss FireMastic-300 to a depth of 50-mm on the exposed end and left open on the unexposed end.
Supports	Approximately 500-mm and 1500-mm away from the wall on the unexposed face.
FIRE STOPPING SYSTEM	
Trade name	FireMastic-300 sealant and Boss P40-MAK wrap
Manufacturer	Boss Fire & Safety Pty Ltd
Description	FireMastic-300 sealant is an intumescent Fire-Rated one part acrylic emulsion sealant. Boss P40-MAK Wrap is a mineral fibre lagging 38-mm thick with a density of 40-kg/m <sup>3</sup> wrap and foil lining on one side.
Application	A surface seal around the pipe was created with a 50-mm fillet of FireMastic-300 sealant on the exposed and unexposed face. The pipe was then lagged with a sheet of Boss P40-MAK Wrap, wrapped twice around the pipe that extended out 300-mm from the FireMastic-300 on both sides of the wall that was secured with foil tape. There was 200-mm of unprotected pipe on the exposed side.
Photograph	 <div style="display: flex; justify-content: space-around; margin-top: 5px;"> <span>Exposed</span> <span>Unexposed</span> </div>
Drawing	CSIRO 0517 – 03 dated 26/05/17 by Boss Fire & Safety.





Specimen 3 – FireMastic-300 sealant protecting a 13-mm diameter aperture penetrated by a single Power Cable.

SEPARATING ELEMENT	
Plasterboard wall system – single layer Boral Firestop 16-mm plasterboard on both sides , with an established FRL of -/90/90	
TYPE AND SIZE OF CONSTRUCTION	
13-mm diameter aperture in a 96-mm thick wall.	
PENETRATING SERVICE	
Description	TPS Cable, 2 core and earth penetrating each side of the wall by 500-mm.
Size	2.5-mm <sup>2</sup> 2C+E TPS power cable.
End conditions	Cables on both the exposed and unexposed side were left untreated.
Supports	Approximately 500-mm away from the wall on the unexposed face.
FIRE STOPPING SYSTEM	
Trade name	FireMastic-300 sealant
Manufacturer	Boss Fire & Safety Pty Ltd
Description	FireMastic-300 sealant is an intumescent Fire-Rated one part acrylic emulsion sealant.
Application	A surface seal around the cable was created with a 50mm fillet of FireMastic-300 intumescent sealant on the exposed and unexposed face.
Photograph	<div>   </div> <div>ExposedUnexposed</div>
Drawing	CSIRO 0517 – 04 dated 26/05/17 by Boss Fire & Safety.



Specimen 4 – FireMastic-300 sealant protecting a 150-mm wide cable tray with 60 cables lagged with Boss P40-MAK Wrap.

SEPARATING ELEMENT	
Plasterboard wall system – single layer Boral Firestop 16-mm plasterboard on both sides , with an established FRL of -/90/90	
TYPE AND SIZE OF CONSTRUCTION	
150-mm wide and 100-mm high aperture in a 96-mm thick wall.	
PENETRATING SERVICE	
Description	Bundle of 60 cables (each cable approximately 14-mm in diameter) secured on a 150-mm cable tray. The services penetrated 500-mm from the exposed side and 800-mm from the unexposed side.
Size	60 x 50 pair, 0.5-mm ( as per Appendix D2 – AS1530.4)
End conditions	Cables on both the exposed and unexposed side were left untreated.
Supports	Approximately 500-mm away from the wall on the unexposed face.
FIRE STOPPING SYSTEM	
Trade name	FireMastic-300 sealant and Boss P40-MAK wrap
Manufacturer	Boss Fire & Safety Pty Ltd
Description	FireMastic-300 sealant is an intumescent Fire-Rated one part acrylic emulsion sealant. Boss P40-MAK is a mineral fibre lagging 38-mm thick with a density of 40-kg/m <sup>3</sup> wrap and foil lining on one side.
Application	A surface seal around the cable tray was created with a 50mm fillet of FireMastic-300 sealant on the exposed and unexposed face. Boss P40-MAK wrap was wrapped twice around the cable tray on both sides of the wall (to a thickness of approximately 40-mm) which was secured with steel wire and foil tape. The wrap extended 300-mm from the both sides of the wall, flush with the FireMastic fillet.
Photograph	<div>  <p>Exposed</p> </div> <div>  <p>Unexposed</p> </div>
Drawing	CSIRO 0517 – 05 dated 26/05/17 by Boss Fire & Safety.



Specimen 5 – FireMastic-300 sealant protecting a 150-mm diameter aperture penetrated by 150-mm Copper pipe lagged with Boss P40-MAK Wrap.

SEPARATING ELEMENT	
Plasterboard wall system – single layer Boral Firestop 16-mm plasterboard on both sides , with an established FRL of -/90/90	
TYPE AND SIZE OF CONSTRUCTION	
150-mm diameter aperture in a 96-mm thick wall.	
PENETRATING SERVICE	
Description	Copper pipe that extends 500-mm on the exposed side and 1100-mm on the unexposed side.
Size	150-mm OD with a wall thickness of 2.03-mm.
End conditions	Sealed on the exposed end using a copper cap and left open on the unexposed end.
Supports	Approximately 500-mm away from the wall on the unexposed face.
FIRE STOPPING SYSTEM	
Trade name	FireMastic-300 sealant and Boss P40-MAK wrap
Manufacturer	Boss Fire & Safety Pty Ltd
Description	FireMastic-300 sealant is an intumescent Fire-Rated one part acrylic emulsion sealant. Boss P40-MAK is a mineral fibre lagging 38-mm thick with a density of 40-kg/m <sup>3</sup> wrap and foil lining on one side.
Application	A surface seal around the pipe was created with a 50mm fillet of FireMastic-300 sealant on the exposed and unexposed face. Two layers of Boss P40-MAK wrap was wrapped approximately twice around the copper pipe to a thickness of 40-mm that were secured with steel wire and foil tape. The wrap extended 300-mm from the exposed side, and 600-mm from the unexposed side; flush with the FireMastic fillet.
Photograph	<div>   </div> <div> Exposed side Unexposed side </div>
Drawing	CSIRO 0517 – 06 dated 26/05/17 by Boss Fire & Safety.

Specimen 6 – FireMastic-300 sealant protecting a 300-mm wide cable tray with a set of 3 and 8 bundle cables lagged with Boss P40-MAK Wrap.

SEPARATING ELEMENT	
Plasterboard wall system – single layer Boral Firestop 16-mm plasterboard on both sides , with an established FRL of -/90/90	
TYPE AND SIZE OF CONSTRUCTION	
300mm wide and 40-mm high aperture (only cut through where the tray and cables leaving no more than an angular gap of approximately 10-mm) in a 96-mm thick wall.	
PENETRATING SERVICE	
Description	A set of three and eight bundle of cables on a steel cable tray. The services penetrated 500-mm from the exposed side and 800-mm from the unexposed side.
Size	3 x 6-mm <sup>2</sup> , 3 core and earth, 8 x 16-mm <sup>2</sup> , 3-core and earth on a 300-mm wide tray.  The tested cables represent the smaller two cable bundles and arrangement as per Appendix D1- AS1530.4 (the 4x185mm <sup>2</sup> and the 1 x 630mm <sup>2</sup> cable from Appendix D1 were omitted.
End conditions	Cables on both exposed and unexposed side were left untreated.
Supports	Approximately 500-mm from the unexposed side.
FIRE STOPPING SYSTEM	
Trade name	FireMastic-300 sealant and Boss P40-MAK wrap
Manufacturer	Boss Fire & Safety Pty Ltd
Description	FireMastic-300 sealant is an intumescent Fire-Rated one part acrylic emulsion sealant. Boss P40-MAK is a mineral fibre lagging 38-mm thick with a density of 40-kg/m <sup>3</sup> wrap and foil lining on one side.
Application	A surface seal around the pipe was created with a 50mm fillet of FireMastic-300 sealant on the exposed and unexposed face. Boss P40-MAK wrap was wrapped twice (to a thickness of about 40-mm) around the cable tray and secured with steel wire and foil tape. The wrap extended 300-mm from both sides of the wall flush with the FireMastic fillet.
Photograph	<div>  </div> <div>  </div> <div>Exposed Side</div> <div>Unexposed side</div>
Drawing	CSIRO 0517 – 07 dated 26/05/17 by Boss Fire & Safety.

Specimen 7 – FireMastic-300 sealant protecting a 32-mm diameter aperture penetrated by a 32-mm Copper pipe lagged with Boss P40-MAK Wrap.

SEPARATING ELEMENT	
Plasterboard wall system – single layer Boral Firestop 16-mm plasterboard on both sides , with an established FRL of -/90/90	
TYPE AND SIZE OF CONSTRUCTION	
32-mm diameter aperture in a 96-mm thick wall.	
PENETRATING SERVICE	
Description	Copper pipe that extended 500-mm from exposed side and 800-mm from the unexposed side.
Size	31.75-mm OD with a wall thickness of 1.22-mm.
End conditions	Plugged with Boss FireMastic-300 to a depth of 50-mm on the exposed end and left open on the unexposed end.
Supports	Approximately 500-mm away from the wall on the unexposed face.
FIRE STOPPING SYSTEM	
Trade name	FireMastic-300 sealant and Boss P40-MAK wrap
Manufacturer	Boss Fire & Safety Pty Ltd
Description	FireMastic-300 sealant is an intumescent Fire-Rated one part acrylic emulsion sealant. Boss P40-MAK is a mineral fibre lagging 38-mm thick with a density of 40-kg/m <sup>3</sup> wrap and foil lining on one side.
Application	A surface seal around the pipe was created with a 50mm fillet of FireMastic-300 sealant on the exposed and unexposed face. Boss P40-MAK wrap was wrapped approximately twice around the copper pipe to a thickness of around 40-mm that were secured with foil tape. The wrap extended 300-mm from both sides of the wall flush with the FireMastic fillet.
Photograph	<div>   </div> <div> Exposed Side Unexposed side </div>
Drawing	CSIRO 0517 – 08 dated 26/05/17 by Boss Fire & Safety.

## 2.2 Dimensions

The overall dimension of the plasterboard wall was 1100-mm wide x 1100-mm long x 96-mm thick, to suit the opening in the specimen containing frame.

## 2.3 Orientation

The plasterboard wall was placed vertically against the furnace chamber, and subjected to fire exposure from one side only.

## 2.4 Conditioning

The specimen was delivered to CSIRO on 4 April 2017.

# 3 Documentation

The following documents were supplied or referenced by the sponsor as a complete description of the specimen and should be read in conjunction with this report:

Drawings numbered CSIRO 0517, numbered 1-8, dated 25<sup>th</sup> May 2017, by Boss Fire & Safety.

# 4 Equipment

## 4.1 Furnace

The furnace had a nominal opening of 1000-mm x 1000-mm for attachment of vertical or horizontal specimens.

The furnace was lined with refractory bricks and materials with the thermal properties as specified in AS 1530.4-2014 and was heated by combustion of a mixture of natural gas and air.

## 4.2 Temperature

The temperature in the furnace chamber was measured by four type K, 3-mm diameter, and 310 stainless steel Mineral Insulated Metal Sheathed (MIMS) thermocouples. Each thermocouple was housed in high-nickel steel tubes opened at the exposed end.

The temperatures of the specimen were measured by glass-fibre insulated and sheathed K-type thermocouples with a wire diameter of 0.5-mm.

Location of the thermocouples on the unexposed face of the specimens are described in Appendix A.

## 4.3 Measurement system

The primary measurement system comprised a multiple-channel data logger, scanning at one minute intervals during the test.

## 5 Ambient temperature

The temperature of the test area was 18°C at the commencement of the test.

## 6 Departure from standard

There were no departures from the requirements of AS 1530.4 – 2014.

## 7 Termination of test

The test was terminated at 92 minutes by the agreement with the sponsor.

## 8 Test results

### 8.1 Critical observations

The following observations were made during the fire-resistance test:

- 1 minute - Smoke being emitted between the cables in Penetration #4. Smoke fluing from the end of pipe in Penetration 1.
- 2 minutes - Smoke from Penetration #1 stopped fluing.
- 3 minutes - Smoke has resumed fluing from Penetration #1. Smoke being emitted between the power cables in Penetration #6.
- 7 minutes - Smoke being emitted from 150-mm copper pipe - Penetration #5  
Material appears to have been combusted in the pipe.
- 13 minutes - Smoke is continuing to be emitted from the end of Penetration 1. The amount of smoke being emitted from Penetration #4 has diminished. Smoke from the cables in Penetration #6 has ceased.
- 26 minutes - Thermocouple #25 was replaced after faulty readings. New thermocouple reading correctly.
- 30 minutes - Smoke from Penetration #1 has ceased.
- 50 minutes - Penetration #1 is fluing again.
- 81 minutes:- Thermocouple mastic on Penetration #7 replaced after falling off.
- 91 minutes - Test terminated.

## 8.2 Furnace temperature

Figure 1 shows the standard curves of temperature versus time for heating the furnace chamber and the actual curves of average and maximum temperature versus time recorded during the heating period.

## 8.3 Furnace severity

Figure 2 shows the curve of furnace severity versus time during the heating period.

## 8.4 Specimen temperature

Figure 3 shows the curve of temperature versus time associated with Penetration 1.

Figure 4 shows the curve of temperature versus time associated with Penetration 2.

Figure 5 shows the curve of temperature versus time associated with Penetration 3.

Figure 6 shows the curve of temperature versus time associated with Penetration 4.

Figure 7 shows the curve of temperature versus time associated with Penetration 5.

Figure 8 shows the curve of temperature versus time associated with Penetration 6.

Figure 9 shows the curve of temperature versus time associated with Penetration 7.

## 8.5 Performance

Performance observed in respect of the following AS 1530.4-2014 criteria:

### Penetration # 1 – 20mm PEX pipe sealed with FireMastic-HPE; in a 60-mm ID hole.

Structural adequacy	-	Not applicable
Integrity	-	no failure at 91 minutes
Insulation	-	no failure at 91 minutes

### Penetration # 2 – FireMastic-300 sealant protecting a 19-mm aperture penetrated by a 19-mm copper pipe lagged with Boss P40-MAK Wrap.

Structural adequacy	-	Not applicable
Integrity	-	no failure at 91 minutes
Insulation	-	no failure at 91 minutes



Penetration # 3 – FireMastic-300 sealant protecting a 13-mm aperture penetrated by a single Power Cable.

Structural adequacy	-	Not applicable
Integrity	-	no failure at 91 minutes
Insulation	-	no failure at 91 minutes

Penetration # 4 – FireMastic-300 sealant protecting a 150mm wide cable tray lagged with Boss P40-MAK Wrap.

Structural adequacy	-	Not applicable
Integrity	-	no failure at 91 minutes
Insulation	-	no failure at 91 minutes

Penetration # 5 – FireMastic-300 sealant protecting a 150-mm aperture penetrated by 150-mm Copper pipe lagged with Boss P40-MAK Wrap.

Structural adequacy	-	Not applicable
Integrity	-	no failure at 91 minutes
Insulation	-	no failure at 91 minutes

Penetration # 6 – FireMastic-300 sealant protecting a 300-mm wide cable tray with a set of 3 and 8 bundle cables lagged with Boss P40-MAK Wrap.

Structural adequacy	-	Not applicable
Integrity	-	no failure at 91 minutes
Insulation	-	no failure at 91 minutes

Penetration # 7 – FireMastic-300 sealant protecting a 32-mm aperture penetrated by a 32-mm Copper pipe lagged with Boss P40-MAK Wrap.

Structural adequacy	-	Not applicable
Integrity	-	no failure at 91 minutes
Insulation	-	no failure at 91 minutes

This report details methods of construction, the test conditions and the results obtained when the specific element of construction described herein was tested following the procedure outlined in this standard. Any significant variation with respect to size, constructional details, loads, stresses, edge or end conditions, other than those allowed under the field of direct application in the relevant test method, is not covered by this report.

Because of the nature of fire resistance testing and the consequent difficulty in quantifying the uncertainty of measurement of fire resistance, it is not possible to provide a stated degree of accuracy of the result.

## 9 Fire-resistance level (FRL)

For the purpose of building regulations in Australia, the FRL's of the test specimens were as follows:

Penetration # 1:-	-/90/90	Penetration # 5:-	-/90/90
Penetration # 2:-	-/90/90	Penetration # 6:-	-/90/90
Penetration # 3:-	-/90/90	Penetration # 7:-	-/90/90
Penetration # 4:-	-/90/90		

The fire-resistance level of the wall system is applicable when the system is exposed to fire from either direction.

The fire-resistance levels (FRL) are limited to that of the separating element.

For the purposes of AS 1530.4-2014 the results of these fire tests may be used to directly assess fire hazard, but it should be noted that a single test method will not provide a full assessment of fire hazard under all fire conditions.

## 10 Field of direct application of test results

The results of the fire test contained in this test report are directly applicable, without reference to the testing authority, to similar constructions where one or more changes listed in Clause 10.12 of AS 1530.4-20014, have been made provided no individual component is removed or reduced.

## 11 Tested by



Heherson Alarde  
Testing Officer


# Appendices

## Appendix A – Measurement location


Specimen	Thermocouple (T/C) position	Thermocouple
Penetration 1 – 20mm PEX pipe sealed with FireMastic-HPE	On plasterboard, 25-mm above mastic	S1
	On plasterboard, 25-mm beside mastic	S2
	On mastic - Top	S3
	On mastic - Side	S4
	On top of pipe 25-mm from mastic	S5
	On side of pipe 25-mm from mastic	S6
Penetration 2 – 19.1mm Copper pipe sealed with 50mm surface fillet of FireMastic-300 and Boss P40-MAK Wrap	On plasterboard – 25-mm above mastic	S7
	On plasterboard – 25-mm beside mastic	S8
	On mastic - Top	S9
	On mastic - Side	S10
	On flex pipe, 25-mm from mastic	S11
	On insulation of 10-mm Cu pipe 25-mm from mastic	S12
	On insulation of 6-mm Cu pipe 25-mm from mastic	S13
Penetration 3 – Bundle of TPS cable. 2.5mm <sup>2</sup> , 2 core & earth TPS cable. Cable sealed with 50-mm surface fillet of FireMastic-300.	On 3-core power cable 25-mm from mastic	S14
	On plasterboard, 25-mm above mastic	S15
	On plasterboard, 25-mm beside mastic	S16
	On mastic fillet - Top	S17
	On mastic fillet - Side	S18
	On cable 25-mm from mastic	S19
Penetration 4 - 60 x 50-pair, 0.5-mm copper telephone cable sealed with 50-mm surface fillet of FireMastic-300 and Boss P40-MAK Wrap	On cable 25-mm from mastic	S20
	On plasterboard, 25-mm above mastic	S21
	On plasterboard, 25-mm beside mastic	S22
	On mastic fillet	S23
	On mastic fillet	S24
	On lagging 25-mm from mastic fillet	S25
	On lagging 25-mm from mastic fillet	S26
	On cable bunch	S27
	On cable bunch	S28
	On cable tray left side	S29
Penetration 5 – 150-mm copper pipe sealed with 50-mm surface fillet of FireMastic-300	On cable tray right side	S30
	On plasterboard, 25-mm from wrap	S31
	On plasterboard, 25-mm from wrap	S32
	On wrap 25-mm from plasterboard	S33
	On wrap 25-mm from plasterboard	S34
	On copper pipe, 25-mm from wrap	S35
	On copper pipe, 25-mm from wrap	S36

Penetration 6 – 3 x 6-mm <sup>2</sup> , 3 core and earth cable, and 8x16-mm <sup>2</sup> , 3 core and earth cable, installed on 300-mm wide tray. Sealed with 50-mm surface fillet of FireMastic300 and BOSS P40-MAK Foil wrap, single layer	On Plasterboard 25-mm from mastic fillet.	S37
	On Plasterboard 25-mm from mastic fillet.	S38
	On mastic fillet 25-mm from p/b	S39
	On mastic fillet 25-mm from p/b	S40
	On wrap 25-mm from mastic fillet	S41
	On wrap 25-mm from mastic fillet	S42
	On cables 3 bunch 25-mm from wrap.	S43
	On cables 8 bunch 25-mm from wrap.	S44
	On cables 8 bunch 25-mm from wrap.	S45
	On cable tray	S46
	On cable tray	S47
Penetration 7 – 32mm copper pipe through 32mm aperture. Sealed with 50mm surface fillet of FireMastic-300 and BOSS P40-MAK Foil wrap, single layer	On mastic fillet 25-mm from p/b	S48
	On mastic fillet 25-mm from p/b	S49
	On mastic fillet	S50
	On mastic fillet	S51
	On wrap 25-mm from mastic fillet	S52
	On wrap 25-mm from mastic fillet	S53
	On pipe 25-mm from wrap	S54
	On pipe 25-mm from wrap	S55
Ambient		S56
Rover		S57

Appendix B – Test photographs



PHOTOGRAPH 1 – EXPOSED SIDE OF THE SPECIMENS PRIOR TO TESTING



PHOTOGRAPH 2 – UNEXPOSED SIDE OF THE SPECIMENS PRIOR TO TESTING





**PHOTOGRAPH 3 – SPECIMENS AFTER 11 MINUTES OF TESTING**



**PHOTOGRAPH 4 – SPECIMENS AFTER 30 MINUTES OF TESTING**



**PHOTOGRAPH 5 – SPECIMENS AFTER 60 MINUTES OF TESTING**



**PHOTOGRAPH 6 – SPECIMENS AT THE CONCLUSION OF TESTING - 90 MINUTES**





**PHOTOGRAPH 7 – EXPOSED FACE OF THE SPECIMENS AFTER THE CONCLUSION OF TESTING**



Appendix C – Test data charts




FIGURE 1 – FURNACE TEMPERATURE




FIGURE 2 – FURNACE SEVERITY




FIGURE 3 – SPECIMEN TEMPERATURE – PENETRATION 1, UNEXPOSED FACE




FIGURE 4 – SPECIMEN TEMPERATURE – PENETRATION 2, UNEXPOSED FACE




FIGURE 5 – SPECIMEN TEMPERATURE – PENETRATION 3, UNEXPOSED FACE




FIGURE 6 – SPECIMEN TEMPERATURE – PENETRATION 4, UNEXPOSED FACE






FIGURE 7 – SPECIMEN TEMPERATURE – PENETRATION 5, UNEXPOSED FACE




FIGURE 8 – SPECIMEN TEMPERATURE – PENETRATION 6, UNEXPOSED FACE







FIGURE 9 – SPECIMEN TEMPERATURE – PENETRATION 7, UNEXPOSED FACE

# Appendix D – Specimen drawings



DRAWING NUMBER CSIRO 0517 -01 DATED 26 MAY 2017, BY BOSS FIRE & SAFETY

Notes

**Component Summary:**

- (1) Plasterboard, 16mm fire-rated
- (2) Hole size 60mm minimum
- (3) 20mm PEX Pipe
- (4) BOSS FireMastic-HPE seal, 16mm deep



Sales & Technical Support  
Ph: 1300 502 677  
[www.bossfire.com.au](http://www.bossfire.com.au)

Drawing Title  
PEX Pipe Penetrating 90min Wall


Description  
FireMastic-HPE Seal

Test Ref  
CSIRO 0517

Date of Issue  
26 May 2017

Drawing Number  
CSIRO 0517 - 02

Drawn By  
SL



DRAWING NUMBER CSIRO 0517 -02 DATED 26 MAY 2017, BY BOSS FIRE & SAFETY

Notes

**Component Summary:**

- (1) Plasterboard, 16mm fire-rated
- (2) BOSS FireMastic-300 seal, 50mm surface fillet
- (3) Copper pipe, 19.05mm diameter
- (4) BOSS P40-MAK Wrap, single layer 300mm from either side of wall.

**BOSS**  
FIRE AND SAFETY  
Sales & Technical Support  
Ph: 1300 502 677  
[www.bossfire.com.au](http://www.bossfire.com.au)

Drawing Title

Copper Pipe Penetrating 90min Wall

Description

FireMastic-300 Surface Seal

Test Ref

CSIRO 0517

Date of Issue


26 May 2017

Drawing Number

CSIRO 0517 - 03

Drawn By

SL




DRAWING NUMBER CSIRO 0517 -03 DATED 26 MAY 2017, BY BOSS FIRE & SAFETY

Notes

**Component Summary:**

- (1) Plasterboard, 16mm fire-rated
- (2) BOSS FireMastic-300 seal, 50mm surface fillet
- (3) TPS cable, 2 core & earth 2.5mm<sup>2</sup>



**BOSS**  
FIRE AND SAFETY  
Sales & Technical Support  
Ph: 1300 502 677  
[www.bossfire.com.au](http://www.bossfire.com.au)

Drawing Title

TPS Cable Penetrating 90min Wall

Description

FireMastic-300 Surface Seal

Test Ref

CSIRO 0517

Date of Issue

26 May 2017


Drawing Number

CSIRO 0517 - 04

Drawn By

SL

DRAWING NUMBER CSIRO 0517 -04 DATED 26 MAY 2017, BY BOSS FIRE & SAFETY

Notes	 <p><b>Component Summary:</b></p> <ul style="list-style-type: none"> <li>(1) Plasterboard, 16mm fire-rated</li> <li>(2) BOSS FireMastic-300 seal, 50mm surface fillet</li> <li>(3) Telco cables, 60 x 50 pair 100 wires, each wire 0.5mm OD (Appendix D2 - AS1530.4)</li> <li>(4) Cable tray, 150mm wide</li> <li>(5) BOSS P40-MAK Wrap, single layer 300mm from either side of wall.</li> </ul>
<p><b>BOSS</b> FIRE AND SAFETY</p> <p>Sales &amp; Technical Support Ph: 1300 502 677 <a href="http://www.bossfire.com.au">www.bossfire.com.au</a></p>	<p>Drawing Title Telco Cables Penetrating 90min Wall</p> <p>Description FireMastic-300 Surface Seal</p> <p>Test Ref CSIRO 0517</p> <p>Date of Issue 26 May 2017</p> <p>Drawing Number CSIRO 0517 - 05</p> <p>Drawn By SL</p>

DRAWING NUMBER 0517 -05 DATED 26 MAY 2017, BY BOSS FIRE & SAFETY

Notes

**Component Summary:**

- (1) Plasterboard, 16mm fire-rated
- (2) BOSS FireMastic-300 seal, 50mm surface fillet
- (3) Copper pipe, 150mm diameter
- (4) BOSS P40-MAK Wrap, dual layer 600mm from either side of wall.

**BOSS**  
FIRE AND SAFETY  
Sales & Technical Support  
Ph: 1300 502 677  
[www.bossfire.com.au](http://www.bossfire.com.au)

Drawing Title  
Copper Pipe Penetrating 90min Wall


Description  
FireMastic-300 Surface Seal

Test Ref  
CSIRO 0517

Date of Issue  
26 May 2017

Drawing Number  
CSIRO 0517 - 06

Drawn By  
SL



**DRAWING NUMBER CSIRO 0517 -06 DATED 26 MAY 2017, BY BOSS FIRE & SAFETY**

Notes

**Component Summary:**

- (1) Plasterboard, 16mm fire-rated
- (2) BOSS FireMastic-300 seal, 50mm surface fillet
- (3) Power cables, 3 x 6mm<sup>2</sup> 3 core & earth, 8 x 16mm<sup>2</sup> 3 core & earth (Appendix D1 - AS1530.4)
- (4) Cable tray, 300mm wide
- (5) BOSS P40-MAK Wrap, single layer 300mm from either side of wall.



Sales & Technical Support  
Ph: 1300 502 677  
[www.bossfire.com.au](http://www.bossfire.com.au)

Drawing Title  
Power Cables Penetrating 90min Wall

Description

FireMastic-300 Surface Seal

Test Ref

CSIRO 0517

Date of Issue


26 May 2017

Drawing Number

CSIRO 0517 - 07

Drawn By

SL



DRAWING NUMBER CSIRO 0517 -07 DATED 26 MAY 2017, BY BOSS FIRE & SAFETY



Notes

**Component Summary:**

- (1) Plasterboard, 16mm fire-rated
- (2) BOSS FireMastic-300 seal, 50mm surface fillet
- (3) Copper pipe, 32mm diameter
- (4) BOSS P40-MAK Wrap, single layer 300mm from either side of wall.



Sales & Technical Support  
Ph: 1300 502 677  
[www.bossfire.com.au](http://www.bossfire.com.au)

Drawing Title

Copper Pipe Penetrating 90min Wall

Description

FireMastic-300 Surface Seal

Test Ref

CSIRO 0517

Date of Issue


26 May 2017

Drawing Number

CSIRO 0517 - 08

Drawn By

SL



DRAWING NUMBER CSIRO 0517 -08 DATED 26 MAY 2017, BY BOSS FIRE & SAFETY

## Appendix E – Certificates of Test

INFRASTRUCTURE TECHNOLOGIES www.csiro.au		
14 Julius Avenue, North Ryde NSW 2113 PO Box 52, North Ryde NSW 1670, Australia T (02) 9490 5444 • ABN 41 687 119 230		
<h3>Certificate of Test</h3>		No. 2967
<small>"Copyright CSIRO 2017 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.</small>		
This is to certify that the element of construction described below was tested by CSIRO Infrastructure Technologies in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4 Fire-resistance tests of elements of construction, 2014 on behalf of:		
Boss Products (Australia) Pty Ltd Unit 8, 15-23 Kumulla Rd Caringbah NSW		
A full description of the test specimen and the complete test results are detailed in the Division's Sponsored Investigation report numbered FSP 1833.		
Product Name: Penetration 1 – FireMastic-HPE sealant protecting a 60-mm diameter aperture penetrated by 20-mm PEX Cross Linked Polyethylene plumbing pipe.		
Description: The Sponsor identified the specimen as a plasterboard wall system comprised of Boral Firestop 16-mm plasterboard both sides (with an established FRL of -/90/90) with FireMastic-HPE sealant protecting a 60-mm diameter aperture penetrated by 20-mm PEX Cross Linked Polyethylene plumbing pipe with a wall thickness of 2.3-mm. The service penetrated the unexposed side by 2000-mm and the exposed side by 500-mm. The pipe was sealed on the exposed end using SmarteX P 20-mm Push fit brass Pex cap and left open on the unexposed end. The pipe was supported approximately 500-mm and 1500-mm away from the wall on the unexposed face. The FireMastic-HPE sealant fire stopping system, manufactured by Boss Fire & Safety Pty Ltd is described as a High Pressure Exerting graphite-based thixotropic acrylic sealant. The annular gap of 20-mm between the pipe and the plasterboard on both the exposed and unexposed face were sealed with BOSS FireMastic-HPE to a depth of 16-mm (the full depth of plasterboard walls) and finished flush with the surface of the wall. For a detailed description, refer to drawing titled CSIRO 0517 – 02 dated 26/05/17 by Boss Fire & Safety.		
Structural Adequacy	not applicable	
Integrity	no failure at 91 minutes	
Insulation	no failure at 91 minutes	
and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/90/90.		
The fire-resistance level of the wall system is applicable when the system is exposed to fire from either direction. The fire-resistance level (FRL) are limited to that of the separating element. This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.		
Testing Officer:	Heherson Alarde	Date of Test: 9 May 2017
Issued on the 20 <sup>th</sup> day of June 2017 without alterations or additions.		
		
Brett Roddy Manager, Fire Testing and Assessments		
	This document is issued in accordance with NATA's accreditation requirements. Accreditation No. 165 – Corporate Site No. 3625 Accredited for compliance with ISO/IEC 17025 - Testing	

**COPY OF CERTIFICATE OF TEST – NO. 2967**



## Certificate of Test

No. 2968

"Copyright CSIRO 2017 ©"  
Copying or alteration of this report  
without written authorisation from CSIRO is forbidden.

This is to certify that the element of construction described below was tested by CSIRO Infrastructure Technologies in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4 Fire-resistance tests of elements of construction, 2014 on behalf of:

Boss Products (Australia) Pty Ltd  
Unit 8, 15-23 Kumulla Rd  
Caringbah NSW

A full description of the test specimen and the complete test results are detailed in the Division's Sponsored Investigation report numbered FSP 1833.

**Product Name:** Penetration 2 – FireMastic-300 sealant protecting a 19-mm diameter aperture penetrated by a 19-mm copper pipe lagged with Boss P40-MAK Wrap.

**Description:** The Sponsor identified the specimen as a plasterboard wall system comprised of Boral Firestop 16-mm plasterboard both sides (with an established FRL of -/90/90) with FireMastic-300 sealant protecting a 19-mm diameter aperture penetrated by a 19-mm copper pipe lagged with Boss P40-MAK Wrap with a wall thickness of 1.02-mm. The service penetrated the unexposed side by 800-mm and the exposed side by 500-mm. The pipe was plugged with Boss FireMastic-300 to a depth of 50-mm on the exposed end and left open on the unexposed end. The pipe was supported approximately 500-mm and 1500-mm away from the wall on the unexposed face. The FireMastic-300 sealant, described as an intumescent Fire-Rated one part acrylic emulsion sealant and Boss P40-MAK wrap fire stopping system, manufactured by Boss Fire & Safety Pty Ltd is described as a mineral fibre lagging 38-mm thick with a density of 40-kg/m<sup>3</sup> wrap and foil lining on one side. A surface seal around the pipe was created with a 50-mm fillet of FireMastic-300 sealant on the exposed and unexposed face. The pipe was then lagged with a sheet of Boss P40-MAK Wrap, wrapped twice around the pipe that extended out 300-mm from the FireMastic-300 on both sides of the wall that was secured with foil tape. There was 200-mm of unprotected pipe on the exposed side. For a detailed description, refer to drawing titled CSIRO 0517 – 03 dated 26/05/17 by Boss Fire & Safety.

Structural Adequacy	not applicable
Integrity	no failure at 91 minutes
Insulation	no failure at 91 minutes

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/90/90.

The fire-resistance level of the wall system is applicable when the system is exposed to fire from either direction. The fire-resistance level (FRL) are limited to that of the separating element. This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.

**Testing Officer:** Heherson Alarde

**Date of Test:** 9 May 2017

Issued on the 20<sup>th</sup> day of June 2017 without alterations or additions.

Brett Roddy  
Manager, Fire Testing and Assessments



This document is issued in accordance with NATA's accreditation requirements.  
Accreditation No. 165 – Corporate Site No. 3625  
Accredited for compliance with ISO/IEC 17025 - Testing

**COPY OF CERTIFICATE OF TEST – NO. 2968**



## Certificate of Test

No. 2969

"Copyright CSIRO 2017 ©"  
Copying or alteration of this report  
without written authorisation from CSIRO is forbidden.

This is to certify that the element of construction described below was tested by CSIRO Infrastructure Technologies in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4 Fire-resistance tests of elements of construction, 2014 on behalf of:

Boss Products (Australia) Pty Ltd  
Unit 8, 15-23 Kumulla Rd  
Caringbah NSW

A full description of the test specimen and the complete test results are detailed in the Division's Sponsored Investigation report numbered FSP 1833.

Product Name: Penetration 3 – FireMastic-300 sealant protecting a 13-mm diameter aperture penetrated by a single Power Cable.

Description: The Sponsor identified the specimen as a plasterboard wall system comprised of Boral Firestop 16-mm plasterboard both sides (with an established FRL of -/90/90) with FireMastic-300 sealant protecting a 13-mm diameter aperture penetrated by a single Power Cable. Cables on both the exposed and unexposed side were left untreated. The pipe was supported approximately 500-mm away from the wall on the unexposed face. The FireMastic-300 sealant, manufactured by Boss Fire & Safety Pty Ltd, is described as an intumescent Fire-Rated one part acrylic emulsion sealant. A surface seal around the pipe was created with a 50-mm fillet of FireMastic-300 sealant on the exposed and unexposed face. For a detailed description, refer to drawing titled CSIRO 0517 – 04 dated 26/05/17 by Boss Fire & Safety.

Structural Adequacy	not applicable
Integrity	no failure at 91 minutes
Insulation	no failure at 91 minutes

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/90/90.

The fire-resistance level of the wall system is applicable when the system is exposed to fire from either direction. The fire-resistance level (FRL) are limited to that of the separating element. This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.

Testing Officer: Heherson Alarde

Date of Test: 9 May 2017

Issued on the 20<sup>th</sup> day of June 2017 without alterations or additions.

Brett Roddy  
Manager, Fire Testing and Assessments



This document is issued in accordance with NATA's accreditation requirements.  
Accreditation No. 165 – Corporate Site No. 3625  
Accredited for compliance with ISO/IEC 17025 - Testing

**COPY OF CERTIFICATE OF TEST – NO. 2969**





## Certificate of Test

No. 2970

"Copyright CSIRO 2017 ©"  
 Copying or alteration of this report  
 without written authorisation from CSIRO is forbidden.

This is to certify that the element of construction described below was tested by CSIRO Infrastructure Technologies in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4 Fire-resistance tests of elements of construction, 2014 on behalf of:

Boss Products (Australia) Pty Ltd  
 Unit 8, 15-23 Kumulla Rd  
 Caringbah NSW

A full description of the test specimen and the complete test results are detailed in the Division's Sponsored Investigation report numbered FSP 1833.

**Product Name:** Penetration 4 – FireMastic-300 sealant protecting a 150-mm wide cable tray with 60 cables lagged with Boss P40-MAK Wrap.

**Description:** The Sponsor identified the specimen as a plasterboard wall system comprised of Boral Firestop 16-mm plasterboard both sides (with an established FRL of -/90/90) with FireMastic-300 sealant protecting a 150-mm wide cable tray with 60 cables lagged with Boss P40-MAK Wrap. The cables are described as a bundle of 60 cables (each cable approximately 14-mm in diameter) secured on a 150-mm cable tray. The services penetrated 500-mm from the exposed side and 800-mm from the unexposed side, measuring 60 x 50 pair, 0.5-mm (as per Appendix D2 – AS 1530.4). Cables on both the exposed and unexposed side were left untreated. The pipe was supported approximately 500-mm away from the wall on the unexposed face. The FireMastic-300 sealant, manufactured by Boss Fire & Safety Pty Ltd, is described as an intumescent Fire-Rated one part acrylic emulsion sealant. The Boss P40-MAK manufactured by Boss Fire & Safety Pty Ltd, is described as a mineral fibre lagging 38-mm thick with a density of 40-kg/m<sup>3</sup> wrap and foil lining on one side. A surface seal around the cable tray was created with a 50mm fillet of FireMastic-300 sealant on the exposed and unexposed face. Boss P40-MAK wrap was wrapped twice around the cable tray on both sides of the wall (to a thickness of approximately 40-mm) which was secured with steel wire and foil tape. The wrap extended 300-mm from the both sides of the wall, flush with the FireMastic fillet. For a detailed description, refer to drawing titled CSIRO 0517 – 05 dated 26/05/17 by Boss Fire & Safety.

Structural Adequacy	not applicable
Integrity	no failure at 91 minutes
Insulation	no failure at 91 minutes

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/90/90.

The fire-resistance level of the wall system is applicable when the system is exposed to fire from either direction. The fire-resistance level (FRL) are limited to that of the separating element. This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.

**Testing Officer:** Heherson Alarde

**Date of Test:** 9 May 2017

Issued on the 20<sup>th</sup> day of June 2017 without alterations or additions.

Brett Roddy  
 Manager, Fire Testing and Assessments



This document is issued in accordance with NATA's accreditation requirements.  
 Accreditation No. 165 – Corporate Site No. 3625  
 Accredited for compliance with ISO/IEC 17025 - Testing

**COPY OF CERTIFICATE OF TEST – NO. 2970**



## Certificate of Test

No. 2971

"Copyright CSIRO 2017 ©"  
 Copying or alteration of this report  
 without written authorisation from CSIRO is forbidden.

This is to certify that the element of construction described below was tested by CSIRO Infrastructure Technologies in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4 Fire-resistance tests of elements of construction, 2014 on behalf of:

Boss Products (Australia) Pty Ltd  
 Unit 8, 15-23 Kumulla Rd  
 Caringbah NSW

A full description of the test specimen and the complete test results are detailed in the Division's Sponsored Investigation report numbered FSP 1833.

**Product Name:** Penetration 5 – FireMastic-300 sealant protecting a 150-mm diameter aperture penetrated by 150-mm Copper pipe lagged with Boss P40-MAK Wrap.

**Description:** The Sponsor identified the specimen as a plasterboard wall system comprised of Boral Firestop 16-mm plasterboard both sides (with an established FRL of -/90/90) with FireMastic-300 sealant protecting a 150-mm diameter aperture penetrated by 150-mm Copper pipe with a wall thickness of 1.02-mm lagged with Boss P40-MAK Wrap. The Copper pipe extends 500-mm on the exposed side and 1100-mm on the unexposed side. The pipe was supported approximately 500-mm away from the wall on the unexposed face. The FireMastic-300 sealant, manufactured by Boss Fire & Safety Pty Ltd, is described as an intumescent Fire-Rated one part acrylic emulsion sealant. The Boss P40-MAK manufactured by Boss Fire & Safety Pty Ltd, is described as a mineral fibre lagging 38-mm thick with a density of 40-kg/m<sup>3</sup> wrap and foil lining on one side. A surface seal around the pipe was created with a 50mm fillet of FireMastic-300 sealant on the exposed and unexposed face. Two layers of Boss P40-MAK wrap was wrapped approximately twice around the copper pipe to a thickness of 40-mm that were secured with steel wire and foil tape. The wrap extended 300-mm from the exposed side, and 600-mm from the unexposed side; flush with the FireMastic fillet. For a detailed description, refer to drawing titled CSIRO 0517 – 06 dated 26/05/17 by Boss Fire & Safety.

Structural Adequacy	not applicable
Integrity	no failure at 91 minutes
Insulation	no failure at 91 minutes

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/90/90.

The fire-resistance level of the wall system is applicable when the system is exposed to fire from either direction. The fire-resistance level (FRL) are limited to that of the separating element. This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.

**Testing Officer:** Heherson Alarde

**Date of Test:** 9 May 2017

Issued on the 20<sup>th</sup> day of June 2017 without alterations or additions.

Brett Roddy  
 Manager, Fire Testing and Assessments



This document is issued in accordance with NATA's accreditation requirements.  
 Accreditation No. 165 – Corporate Site No. 3625  
 Accredited for compliance with ISO/IEC 17025 - Testing

**COPY OF CERTIFICATE OF TEST – NO. 2971**



## Certificate of Test

No. 2972

"Copyright CSIRO 2017 ©"  
Copying or alteration of this report  
without written authorisation from CSIRO is forbidden.

This is to certify that the element of construction described below was tested by CSIRO Infrastructure Technologies in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4 Fire-resistance tests of elements of construction, 2014 on behalf of:

Boss Products (Australia) Pty Ltd  
Unit 8, 15-23 Kumulla Rd  
Caringbah NSW

A full description of the test specimen and the complete test results are detailed in the Division's Sponsored Investigation report numbered FSP 1833.

**Product Name:** Penetration 6 – FireMastic-300 sealant protecting a 300-mm wide cable tray with a set of 3 and 8 bundle cables lagged with Boss P40-MAK Wrap.

**Description:** The Sponsor identified the specimen as a plasterboard wall system comprised of Boral Firestop 16-mm plasterboard both sides (with an established FRL of -/90/90) with FireMastic-300 sealant protecting a 300-mm wide cable tray with a set of 3 and 8 bundle cables lagged with Boss P40-MAK Wrap. The services penetrated 500-mm from the exposed side and 800-mm from the unexposed side. Measurements of penetrating service are 3 x 6-mm<sup>2</sup>, 3 core and earth, 8 x 16-mm<sup>2</sup>, 3-core and earth on a 300-mm wide tray. Tested cables represent the smaller two cable bundles and arrangement as per Appendix D1- AS1530.4 (the 4x185mm<sup>2</sup> and the 1 x 630mm<sup>2</sup> cable from Appendix D1 were omitted. Cables on both exposed and unexposed side were left untreated. The penetrating services was supported approximately 500-mm from the unexposed side. The FireMastic-300 sealant, manufactured by Boss Fire & Safety Pty Ltd, is described as an intumescent Fire-Rated one part acrylic emulsion sealant. The Boss P40-MAK manufactured by Boss Fire & Safety Pty Ltd, is described as a mineral fibre lagging 38-mm thick with a density of 40-kg/m<sup>3</sup> wrap and foil lining on one side. A surface seal around the pipe was created with a 50mm fillet of FireMastic-300 sealant on the exposed and unexposed face. Boss P40-MAK wrap was wrapped twice (to a thickness of about 40-mm) around the cable tray and secured with steel wire and foil tape. The wrap extended 300-mm from both sides of wall flush with the FireMastic fillet. For a detailed description, refer to drawing titled CSIRO 0517 – 07 dated 26/05/17 by Boss Fire & Safety.

Structural Adequacy	not applicable
Integrity	no failure at 91 minutes
Insulation	no failure at 91 minutes

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/90/90.

The fire-resistance level of the wall system is applicable when the system is exposed to fire from either direction. The fire-resistance level (FRL) are limited to that of the separating element. This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.

**Testing Officer:** Heherson Alarde

**Date of Test:** 9 May 2017

Issued on the 20<sup>th</sup> day of June 2017 without alterations or additions.

Brett Roddy  
Manager, Fire Testing and Assessments



This document is issued in accordance with NATA's accreditation requirements.  
Accreditation No. 165 – Corporate Site No. 3625  
Accredited for compliance with ISO/IEC 17025 - Testing

**COPY OF CERTIFICATE OF TEST – NO. 2972**





## Certificate of Test

No. 2973

"Copyright CSIRO 2017 ©"  
 Copying or alteration of this report  
 without written authorisation from CSIRO is forbidden.

This is to certify that the element of construction described below was tested by CSIRO Infrastructure Technologies in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4 Fire-resistance tests of elements of construction, 2014 on behalf of:

Boss Products (Australia) Pty Ltd  
 Unit 8, 15-23 Kumulla Rd  
 Caringbah NSW

A full description of the test specimen and the complete test results are detailed in the Division's Sponsored Investigation report numbered FSP 1833.

**Product Name:** Penetration 7 – FireMastic-300 sealant protecting a 32-mm diameter aperture penetrated by a 32-mm Copper pipe lagged with Boss P40-MAK Wrap.

**Description:** The Sponsor identified the specimen as a plasterboard wall system comprised of Boral Firestop 16-mm plasterboard both sides (with an established FRL of -/90/90) with FireMastic-300 sealant protecting a 32-mm diameter aperture penetrated by a 32-mm Copper pipe with a wall thickness of 1.22-mm. The services extended 500-mm from exposed side and 800-mm from the unexposed side. The penetrating service was plugged with Boss FireMastic-300 to a depth of 50-mm on the exposed end and left open on the unexposed end. The penetrating service was supported approximately 500-mm from the unexposed side. The FireMastic-300 sealant, manufactured by Boss Fire & Safety Pty Ltd, is described as an intumescent Fire-Rated one part acrylic emulsion sealant. The Boss P40-MAK manufactured by Boss Fire & Safety Pty Ltd, is described as a mineral fibre lagging 38-mm thick with a density of 40-kg/m<sup>3</sup> wrap and foil lining on one side. A surface seal around the pipe was created with a 50mm fillet of FireMastic-300 sealant on the exposed and unexposed face. Boss P40-MAK wrap was wrapped approximately twice around the copper pipe to a thickness of around 40-mm that were secured with foil tape. The wrap extended 300-mm from both sides of the wall flush with the FireMastic fillet. For a detailed description, refer to drawing titled CSIRO 0517 – 08 dated 26/05/17 by Boss Fire & Safety.

Structural Adequacy	not applicable
Integrity	no failure at 91 minutes
Insulation	no failure at 91 minutes

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/90/90.

The fire-resistance level of the wall system is applicable when the system is exposed to fire from either direction. The fire-resistance level (FRL) are limited to that of the separating element. This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.

Testing Officer: Heherson Alarde

Date of Test: 9 May 2017

Issued on the 20<sup>th</sup> day of June 2017 without alterations or additions.

Brett Roddy  
 Manager, Fire Testing and Assessments



This document is issued in accordance with NATA's accreditation requirements.  
 Accreditation No. 165 – Corporate Site No. 3625  
 Accredited for compliance with ISO/IEC 17025 - Testing

**COPY OF CERTIFICATE OF TEST – NO. 2973**



## References

The following informative documents are referred to in this Report:

- |                |   |
|----------------|---|
| AS 1530.4-2014 | Methods for fire tests on building materials, components and structures Part 4: Fire-resistance tests of elements of building construction. |
| AS 4072.1-2005 | Components for the protection of openings in fire-resistant separating elements. Part 1: Service penetrations and control joints.           |

**END OF REPORT**

#### CONTACT US

**t** 1300 363 400  
+61 3 9545 2176  
**e** [enquiries@csiro.au](mailto:enquiries@csiro.au)  
**w** [www.csiro.au](http://www.csiro.au)

#### YOUR CSIRO

Australia is founding its future on science and innovation. Its national science agency, CSIRO, is a powerhouse of ideas, technologies and skills for building prosperity, growth, health and sustainability. It serves governments, industries, business and communities across the nation.

#### FOR FURTHER INFORMATION

##### **Infrastructure Technologies**

Chris Wojcik  
Manager Fire Resistance Testing  
**t** +61 2 9490 5508  
**e** [chris.wojcik@csiro.au](mailto:chris.wojcik@csiro.au)  
**w** [www.csiro.au/Organisation-Structure/Divisions/CMSE/Infrastructure-Technologies/Fire-safety.aspx](http://www.csiro.au/Organisation-Structure/Divisions/CMSE/Infrastructure-Technologies/Fire-safety.aspx)

##### **Infrastructure Technologies**

Brett Roddy  
Team Leader, Fire Testing and Assessments  
**t** +61 2 94905449  
**e** [brett.rodny@csiro.au](mailto:brett.rodny@csiro.au)  
**w** [www.csiro.au/Organisation-Structure/Divisions/CMSE/Infrastructure-Technologies/Fire-safety.aspx](http://www.csiro.au/Organisation-Structure/Divisions/CMSE/Infrastructure-Technologies/Fire-safety.aspx)