

VOC Content Test Certificate

Wednesday 11th August 2021

Supplier: BOSS Products (Australia) Pty Ltd (Unit 1, 16 Atkinson Rd, Taren Point, NSW, 2229, AUSTRALIA).

Sample Description: FireSilicone - EMA

Date Tested: August 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:


Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	FireSilicone - EMA
Acoustic sealants, architectural sealant, waterproofing membranes and sealant, Fire Retardant Sealants and Adhesives: ≤ 250 grams per liter	41 grams per Litre as VOC content per material
Meets GBCA VOC Content Requirement	Yes



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant



Dr. Tuan Duong
 PhD, BE (Chem. Eng.)
 Senior Consultant



Srikanth C Srivatsa
 PhD (Chemistry)
 Consultant

V2108022